Brand på en destillationsanläggning i petrokemisk industri.

941107 MARS 1994_01

Vid reparationsarbete på en bensinstabiliseringskolonn antändes bensin och en anställd omkom till följd av de brännskador han ådrog sig.

Inblandade ämnen och mängder

CAS Nr. Mängd brandfarlig vätska 800-1500 kg

Skador:

Människor: 1 person omkom i branden.

Materiella: Begränsade brandskador på anläggningen.

Miljö/ekologi: Inga effekter rapporterade.

Infrastruktur: Inga

Erfarenheter redovisade (Ja/Nej): Nej

Report Profile

Authority Reporting:

Authority Contact:

rep_cont_name: rep_cont_phone:

name: address:

Identification of Report: country: FA ident key: 1994 001 01 reported under Seveso I directive as major accident reports: SHORT Date of Major Occurrence: Time of Major Occurrence start: 1994-11-07 start: finish: finish: **Establishment:** name: address: industry: - not applicable -Distillation or Refining or other mechanical Treatments of Petroleum or Lubricant Refining Seveso II status: not applicable: Yes art. 6 (notification): No art. 7 (MAPP): No art. 9 (safety report): No **Date of Report:** short: full:

rep_cont_fax:
Additional Comments:
a) - not applicable -
b) - not applicable -
c) - not applicable -
d) - not applicable -
e) - not applicable -
Short Report
country: FA ident key: 1994_001_01
Accident Types:
release: No explosion: No
water contamination: No other: No
fire: Yes
description:
During repair works a gasoline stabilization column, in the crud eoil station plant, was put out of gear. The
repair works were necessary for exchanging a leaky nest of boiler tubes of a water cooler. For this the column
system should be cl see Appendix Short Report / description of accident types
Substance(s) Directly Involved:
toxic: No explosive: No
ecotoxic: No other: No
flammable: Yes
description:
High flammable liquid (ca $800 \sim 1500 \text{ kg}$)
Immediate Sources of Accident:
storage: No transfer: No
process: No other: No
description:
- not applicable -
Suspected Causes:
plant or equipment: No environmental: No
human: No other: Yes
description:
The cause of the benzine ignition is still unknown
Immediate Effects:

material loss: Yes

human deaths: Yes

other: No

human injuries: No community disruption: No

ecological harm: No

national heritage loss: No

description:

One person killed by the fire;

Material damage amounting at 1.300.000 DM

Emergency Measures taken:

on-site systems: Yes decontamination: No

external services: Yes restoration: No

sheltering: No other: No

evacuation: No

description:

The fire was put under control and then extinguished by the internal fire brigade and by the firemen of the

city of Karlsruhe.

Immediate Lessons Learned:

prevention: No other: No

mitigation: No

description:

- not applicable -

Appendices for the FA / 1994_001_01 report

Appendix Short Report / description of accident types:

During repair works a gasoline stabilization column, in the crud eoil station plant, was put out of gear. The repair works were necessary for exchanging a leaky nest of boiler tubes of a water cooler. For this the column system should be cleared and inerted, so the inlet and the outlet pipes in the water cooler had to be set out by plugs; the column system was closed, emptied by pumps, tempered and rinsed by steam.

The gasoline still remaining near the extraction pump, in the lower points was under constant control of weak flowing off of discharging quantities like water addition for cooling and diluition. Nevertheless the escaping gasoline ignited. Consequently caused to the competent plant driver the worst fire injuries, which caused his death.