Naturgasutsläpp från en petrokemisk anläggning.

970706

Till följd av en blockerad rörledning uppstod en överhettning av gasen och trycket steg. Säkerhetsventilen öppnades automatiskt, men slöts inte som den skulle efteråt. Gasmolnet skingrades utan att antändas. Olyckans orsak tillskrevs både bristfälliga procedurer och en bristfällig säkerhetsventil.

Inblandade ämnen och mängder

metan CAS Nr. Mängd
ca 106 ton

Skador:

Människor: Det noteras att lokalbefolkningen klagade över dålig hälsa som en följd

av utsläppet, men det avfärdas med att detta är ett ständigt klagomål.

Materiella: Inga skador.

Miljö/ekologi: Inga effekter rapporterade.

Infrastruktur: Inga effekter.

Erfarenheter redovisade (Ja/Nej): Ja

Kortfattat anges förebyggande åtgärder

Report Profile

Identification of Report:

country: FA ident key: 1800_013_01

reported under Seveso I directive as major accident reports: SHORT

Date of Major Occurrence: Time of Major Occurrence

start: 06/07/1997 start: 16:10:00

finish: 06/07/1997 finish: 19:45:00

Establishment:

name:

address:

industry: 2002 petrochemical, refining, processing

Seveso II status: not applicable: Yes art. 6 (notification): No

art. 7 (MAPP): No

art. 9 (safety report): No

Date of Report:

short: full:

Authority Reporting:

name:

address:

Authority Contact:

rep_cont_name:

rep_cont_phone:

rep_cont_fax: **Additional Comments:** a) - not applicable b) - not applicable c) - not applicable d) - not applicable e) - not applicable -**Short Report** country: FA ident key: 1800_013_01 **Accident Types:** release: Yes explosion: No water contamination: No other: No fire: No description: Release reportable because: 1) It was an uncontrolled event, 2) There was danger created to people on-site, 3) It involved the substance that gives the site CIMAH status. **Substance(s) Directly Involved:** toxic: No explosive: No ecotoxic: No other: No flammable: Yes description: Natural Gas (methane etc.), about 106 tonnes **Immediate Sources of Accident:** storage: No transfer: No process: Yes other: No description: Release from slue-catcher on gas inlet to site from North Sea. Slue-catcher shut in. Pressure in slue-catcher rose due to thermal expansion. PRV lifted, but failed to re-seat. **Suspected Causes:** plant or equipment: Yes environmental: No human: Yes other: No description:

1) Operating at pressure to close to PRV setting with no appreciation that thermal expansion could occur. 2)

Maintenence of PRV - its failure to reseat was due to internal damage. 3) Poor commissioning of PRV isolation

valves, which failed \dots see Appendix Short Report / description of suspected causes

Immediate Effects:

material loss: Yes

human deaths: No

human injuries: No community disruption: No

other: No

ecological harm: No

national heritage loss: No

description:

No on-site of off-site site effects, no ignition gas dispersed. Local residents alleging ill health as a

consequence, but this is part of a long term ongoing complaint.

Emergency Measures taken:

on-site systems: Yes decontamination: No

external services: No restoration: No

sheltering: No other: No

evacuation: No

description:

not necessary to take emergency measures.

Immediate Lessons Learned:

prevention: Yes other: No

mitigation: No

description:

 $1) Change \ to \ operating \ parameters \ and \ procedures \ - \ PN \ is sued \ requiring \ such \ changes. \ Re-setting \ of \ alarms \ to$

identify pressure rise, with manual controlled venting if necessary.

Appendices for the FA / 1800_013_01 report

Appendix Short Report / description of suspected causes:

1) Operating at pressure to close to PRV setting with no appreciation that thermal expansion could occur. 2) Maintenence of PRV - its failure to reseat was due to internal damage. 3) Poor commissioning of PRV isolation valves, which failed to work.